

[illegible]

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
Road	Illuminance	Fc	2.35	7.3	0.3	7.83	23.83

① PROVIDE EXTERIOR LIGHT STANDARD OF TOTAL MOUNTING HEIGHT 4.5M. c/w POLE 13 FEET ON 2'-0" CONCRETE BASE. REFER TO DETAIL 2 FOR TYPICAL LIGHT POLE BASE DETAIL.

② PROVIDE BACK LIGHT CONTROL TO AVOID LIGHT SPILLAGE.

- * PROVIDE LIGHTING IN ACCORDANCE WITH STANDARD GUIDELINES & CODES WITH RESPECT TO PUBLIC SAFETY. SITE LIGHTING IS TO LIGHT THE GROUND DIRECTLY TO AVOID LIGHT POLLUTION.
- * NUMERICAL VALUES ARE SHOWN IN FOOTCANDLE. ALL SELECTED FIXTURES ARE DARK SKY COMPLIANT.

LS - LIGHT STANDARD
W - WALL PACK
L - LIGHT
N - CANOPY RECESSED DOWN LIGHT
MH - MOUNTING HEIGHT (METER)FROM
FINISH GRADE LEVEL

METEOR meteor-lighting.com

[illegible]

currentlighting.com/beacon

currentlighting.com/prescolite
Page 1 of 9
 © 2010 HCL Solutions, Inc. All rights reserved. Information and specifications subject to change without notice. All values are design or typical values after measured under laboratory conditions.
Rev 10/09/09
(78-480)_R02

C	AUG. 27, 2024	ISSUED FOR SPA
---	---------------	----------------

Project

Burlington, Ontario L7L 5H9 millenn@mill-eng.com

SCALE **1:125** DATE **DEC 2020**

.....

PHOTOMETRIC DATA20-033 EUTSP 20-033

E01SP_c