
SS WILSON ASSOCIATES

Consulting Engineers

April 30, 2018

Mr. Michael Hall
Condeland Engineering Limited
350 Creditstone Road, Unit 200
Concord, Ontario, L4K 3Z2

Email: mike@condeland.com

Dear Mike:

**Re: Noise Impact Confirmation Letter
Proposed Residential Development
Eden Oak Development
McMaster Street and Meagan Drive, Halton Hills
Town File No.: 24T-09001/H
SSWA File No.: WA10-096**

This letter is in response to the Town of Halton Hills' comments (comment no. 2.3) received by email on April 2, 2018, regarding the need for a Noise Impact Study for the above development.

Upon examination of the location of the subject development, it is noted that there is a considerable distance setback (i.e. approximately 400 meters) to the nearest major roadway, Main Street North, with several rows of intervening dwellings. Furthermore, the development is not in close proximity to any arterial roads that carry significant traffic. Therefore, traffic noise is not of concern for noise.

In addition, the subject development is not in close proximity to any stationary sources of noise.

Based on our examination of the neighbourhood and the received project drawings, it is concluded that there is no need for a noise impact study for this proposed development.

If you have any questions or concerns, please do not hesitate to contact our office.

Approved by,



Hazem Gidamy, M.Eng., P.Eng.
Principal

SSWA INC. 15 Wertheim Court, Suite 211, Richmond Hill, Ontario, L4B 3H7

**Tel: (905) 707-5800 Fax: (905) 707-5801 e-mail: engineering@sswilsonassociates.com
www.sswilsonassociates.com & www.noisetraining.com**