



Environment  
Canada

Environnement  
Canada

Meteorological  
Service of  
Canada

Service  
météorologique  
du Canada

Engineering Climate Services Unit  
Water and Climate Services Division  
Meteorological Service of Canada  
Environment Canada  
4905 Dufferin Street  
Toronto, ON M3H 5T4

January 22, 2013

Building Engineer  
Building Services  
Infrastructure Services  
1 Halton Hills Drive  
Halton Hills, ON L7G 5G2

I have reviewed the map you sent and have determined that three ground snow load zones will be sufficient for your municipality. The northwestern zone (including Acton) has a 50-year ground snow load of 1.9 kPa and the southeastern zone (including Georgetown) has a 50-year ground snow load of 1.4 kPa. The final zone lies along the escarpment between the other two zones and covers the transition across the escarpment.

The zone along the escarpment is bounded by the 305 metre and 275 metre contour lines. Within this zone the snow loads vary linearly with elevation from 1.4 kPa at 275 metres to 1.9 kPa at 305 metres. The jpg file I e-mailed with this letter, Halton\_Hills\_Snow\_Loads\_2013-01-22.jpg, shows the rough outline of these zones.

If you have any questions or concerns, please do not hesitate to contact me by phone at: (416) 739-4962 or by e-mail at: philip.jarrett@ec.gc.ca.

Yours,

*Philip L. Jarrett*

Philip L. Jarrett  
Engineering Climate Services Unit

EcoLogo® Papier/Paper/Eco-Logo®



Canada