

MEMO

| | | | |
|-------------|--|--------------------|-----------|
| DATE | October 21, 2020 | PROJECT NO. | 1967-5752 |
| RE | 71 Main Street South Town of Halton Hills | | |

| | |
|-------------|---|
| TO | Planning and Development, Town of Halton Hills |
| FROM | Madeline Carter, P.Eng. & Nick Constantin, P.Eng. |
| CC | Cindy Prince, Vice President, Amico Affiliates |

This memo was prepared as an update to the previously approved Functional Servicing & Stormwater Management Report prepared by Crozier on August 15, 2017 for the development located at 69-79 Main Street South and 94-98 Mill Street, in the Town of Halton Hills.

The proposed development concept has been modified slightly from the previous design. The number of residential units has been increased to 169 from 125. The commercial area has been reduced from 1,667 m² to 369 m², with the residential area increasing from 13,412 m² to 15,578 m². The total gross floor area (GFA) of 17,431 m² of the proposed development concept has decreased slightly from the previous design which had a GFA of 18,194 m². The equivalent population was calculated based on 1.68 people per unit, which was provided by the Region in 2015.

Table 1: Equivalent Population Calculation for Residential Use

| Scenario | Number of Units | Equivalent Population |
|--|-----------------|-----------------------|
| Proposed Concept – Approved FSR August 15, 2017 | 125 | 210 |
| Proposed Development Concept Plan June 15, 2020 | 169 | 284 |

The servicing calculations for water demand and sanitary flow, as well as the Fire Flow calculations have been updated to reflect the latest Site Statistics as provided on the Site Plan prepared by IBI Group Architects, dated June 15, 2020. The design calculations, as well as an updated Water Usage and Sanitary Discharge Report have been provided with this memo.

Water Servicing

The water demand calculations were updated based on the revised development concept plan. The increase in number of units results in an increase in the water demand compared to the previously approved calculations. The maximum daily domestic water demand increased 0.45 L/s as seen below in Table 2. The existing demand scenario presented is from the FSR (August 2017) and is based on the current use of the building.

Table 2: Water Demand Calculations

| Scenario | Land Use | Average Daily Demand (L/s) | Maximum Daily Demand (L/s) | Maximum Hourly Demand (L/s) |
|--|-----------------|----------------------------|----------------------------|-----------------------------|
| Existing Demand August 15, 2017 | Residential | 0.24 | 0.55 | 0.97 |
| | Commercial | 0.04 | 0.10 | 0.10 |
| | Combined | 0.28 | 0.64 | 1.07 |
| Proposed Demand – Approved FSR August 15, 2017 | Residential | 0.67 | 1.50 | 2.67 |
| | Commercial | 0.05 | 0.11 | 0.11 |
| | Combined | 0.72 | 1.61 | 2.78 |
| Proposed Development Concept Plan June 15, 2020 | Residential | 0.90 | 2.03 | 3.61 |
| | Commercial | 0.01 | 0.02 | 0.02 |
| | Combined | 0.91 | 2.06 | 3.64 |

The fire flow calculations were updated for the new development concept using the Fire Underwriter's Survey. We confirmed the type of construction (non-combustible), occupancy reduction (low hazard) and the type of sprinkler system (NFPA) with the Client. The fire flow decreased slightly from the previous approved design with a new requirement of 13,269 L/min (221.15 L/s) for a duration of 3.0 hours.

Please note that the Fire Underwriters Survey calculated value for the estimated fire flow is a conservative estimate. The Mechanical Engineer should review and prepare detailed fire calculations for the proposed building concept.

A hydrant flow test was previously completed for the property by Vipond on September 14, 2015. Results from the test indicated that at 20 psi residual pressure in the municipal watermain, a minimum of 6000 US GPM (378.54 L/s) is projected to be available within the municipal system. As such, we anticipate that the marginal increase in demand as a result of the modified building concept will not be a concern, and the water services remain sufficient to meet the demands of the proposed development.

Sanitary Servicing

The sanitary servicing calculations were updated based on the proposed development concept and the Region of Halton Water and Wastewater Linear Design Manual, dated April 2019. The commercial area in the proposed development concept is smaller than the previously approved design. The additional residential units and reduced commercial area result in an increase of 0.79 L/s for the sanitary design flow. The existing condition presented is from the FSR (August 2017) and is based on the current use of the building.

Table 3: Sanitary Flow Calculations

| Condition | Land Use | Average Flow (L/s) | Peaking Factor | Peak Flow (L/s) | Infiltration Flow (L/s) | Total Flow (L/s) |
|--|-----------------|--------------------|----------------|-----------------|-------------------------|------------------|
| Existing Aug 15, 2017 | Residential | 0.24 | 3.85 | 0.92 | 0.08 | 1.18 |
| | Commercial | 0.04 | | 0.15 | | |
| | Combined | 0.29 | | 1.10 | | |
| Proposed Approved FSR Aug 15, 2017 | Residential | 0.67 | 4.14 | 2.77 | 0.08 | 3.01 |
| | Commercial | 0.05 | 3.52 | 0.17 | | |
| | Combined | 0.72 | - | 2.94 | | |
| New Site Plan June 15, 2020 | Residential | 0.90 | 4.07 | 3.72 | 0.08 | 3.80 |
| | Commercial | 0.01 | | | | |
| | Combined | 0.91 | | | | |

Conclusions & Recommendations

Based on the information contained in this memo, we offer the following conclusions:

- The revised building concept results in a marginal increase in water demand, which we anticipate can be accommodated by the existing infrastructure. The proposed development, with a maximum hourly demand of 3.64 L/s can be serviced by the existing municipal watermain infrastructure.
- The revised building concept results in a design sanitary flow of 3.80 L/s, which is also a slight increase in flows from the previously approved design. We anticipate that this will not generate any concern related to the available capacity of the municipal sanitary system.

Based on the aforementioned conclusions and recommendations, we suggest the approval of the Site Plan Application from the perspective of functional servicing.

Sincerely,

C.F. CROZIER & ASSOCIATES INC.



Madeline Carter, P.Eng.
Project Engineer

C.F. CROZIER & ASSOCIATES INC.



Nick Constantin, P.Eng.
Senior Project Manager

DD/MC/kb

Encl.

- Water Demand Calculation – Revised October 2020
- Fire Flow Calculations – Revised October 2020
- Sanitary Flow Calculations – Revised October 2020
- Water Usage and Sanitary Discharge Report

REVISED - Domestic Water Demand

Project: 71 Main Street Development
Job No.: 1967-5752

Revised: 20-Oct-20

Proposed Site Conditions

A. Proposed Units

| | |
|---------------|------------|
| One Bedroom | 68 |
| Two Bedroom | 94 |
| Three Bedroom | 7 |
| TOTAL | 169 |

B. Area's

(m²)

| | |
|------------------------------|---------|
| Total Residential Units GFA | 15,578 |
| Commercial and Amenities GFA | 369 |
| Site Area | 2,773.0 |

C. Design Criteria

Population per Hectare¹ = $\frac{1.68 \text{ ppu} * (\# \text{ units})}{\text{area}}$

Population per Hectare = 1,024 p/ha
 Total Population = 284

Note 1: Apartment population density Population density per email confirmation from Tim Skrips - Region of Halton, dated September 29, 2015

Residential Average Consumption Rate²= 275.0 L/cap/d
 Apartments Max Day Factor² = 2.25
 Apartments Peak Hour Factor² = 4.0

| | | | | | | | | | | | |
|--------------------|-----|---|-----|---|------|---|---------|-------|---|------|-----|
| Average Day Demand | 275 | x | 284 | = | | | 78,078 | L/day | = | 0.90 | L/s |
| Maximum Day Demand | 275 | x | 284 | x | 2.25 | = | 175,676 | L/day | = | 2.03 | L/s |
| Peak Hour Demand | 275 | x | 284 | x | 4.0 | = | 312,312 | L/day | = | 3.61 | L/s |

Note 3: Average Consumption Rate, Max day Factor and Peak Hour Factor each determined from Section 2.4, Halton Water Wastewater Linear Design Manual

D. Commercial

Approximate floor area of the proposed commercial **Total = 369.00 sq.m**

Commercial Average Consumption Rate³= 24,750.0 L/ha/day

| | | | | | |
|---------------------------|--|--|---------|------------|------------|
| Retail population density | | | 90.00 | persons/ha | |
| Equivalent population | | | 90.00 * | 0.0369 | = 3 people |

Commercial Max Day Factor³ = 2.25
 Commercial Peak Hour Factor³ = 2.25

Note 4: Average Consumption Rate, Max day Factor and Peak Hour Factor each determined from Section 2.4, Halton Water Wastewater Linear Design Manual

E. Commercial Demands

| | | | | | | | | | | | |
|--------------------|--------|---|------|---|------|-------|-------|-------|-----|------|-----|
| Average Day Demand | 24,750 | x | 0.04 | = | 900 | L/day | = | 0.01 | L/s | | |
| Maximum Day Demand | 24,750 | x | 0.04 | x | 2.25 | = | 2,100 | L/day | = | 0.02 | L/s |
| Peak Hour Demand | 24,750 | x | 0.04 | x | 2.25 | = | 2,100 | L/day | = | 0.02 | L/s |

F. Total Domestic Demand (Residential + Retail)

| | | | | | | | | | | | |
|--------------------|------------|--|--|---|-------|---|---------|-------|---|-------------|------------|
| Average Day Demand | 78,078.00 | | | + | 900 | = | 79,000 | L/day | = | 0.91 | L/s |
| Maximum Day Demand | 175,675.50 | | | + | 2,100 | = | 177,800 | L/day | = | 2.06 | L/s |
| Peak Hour Demand | 312,312.00 | | | + | 2,100 | = | 314,400 | L/day | = | 3.64 | L/s |

Note 5: Average consumption rate, max day factor and peak hour factor per Section 2.4, Halton Water Wastewater Linear Design Manual

FIRE FLOW CALCULATIONS
PRELIMINARY ESTIMATES FOR CONFIRMATION OF CAPACITY STATEMENT

Project: McGibbon Development 71 - 79 Main Street South
Job No.: 1967-5752

Date: 10/20/2020

Fire flow required for a given area based on Fire Underwriters Survey (FUS) Water Supply for Public Fire Protection (1999)

$$F = 220 C \sqrt{A}$$

where

- F = Fire flow in Litres per minute (Lpm)
- C = coefficient related to the type of construction
 - = 1.5 for wood frame construction (structure essentially all combustible)
 - = 1.0 for ordinary construction (brick or other masonry walls, combustible floor and interior)
 - = 0.8 for non-combustible construction (unprotected metal structural components)
 - = 0.6 for fire-resistive construction (fully protected frame, floors, roof)
- A = total floor area in square metres

Calculations per FUS

1. *Estimate of Fire Flow*
 C = 0.8 for non-combustible construction Per email with Amico dated October 15, 2020

Largest Podium GFA

| Level | GFA | Applied GFA |
|--------------|------|-------------|
| 1 | 2452 | 2452 |
| 2 | 2089 | 522 |
| 3 | 2089 | 522 |
| Total | | 3497 |

A = 2452 m² (largest GFA plus 25% of GFA for two immediately adjoining floors)¹

F = 10,407 Lpm

2. *Occupancy Reduction*
 15% reduction based on low hazard occupancy ('apartments, Office Buildings, Public Buildings')
 Limited Combustibility Per email with Amico dated October 15, 2020
 15% reduction of 10407 Lpm = 1,561 Lpm
 F = 10407 - 1561 = 8,846 Lpm

3. *Sprinkler Reduction*
 30% reduction for NFPA Sprinkler System² Per email with Amico dated October 15, 2020
 30% reduction of 8846 Lpm = 2,654 Lpm
 F = 8846 - 2654 = 6,192 Lpm

4. *Separation Charge*

| Face | Distance (m) | Charge |
|--------------|--------------|------------|
| West Side | 20.00 | 15% |
| East Side | 0.00 | 25% |
| North Side | 0.00 | 25% |
| South Side | 15.00 | 15% |
| Total | | 80% |

of 8,846 = 7,077 Lpm

F = 6192 + 7077
 F = 13,269 Lpm 221.15 L/s (2,000 Lpm < F < 45,000 Lpm; OK)
 F = 3,501 US GPM

Notes

1. GFA based on data provided by IBI Group Architects on Site Stats dated June 15, 2020
2. Assumed to have sprinkler protection.

FIRE FLOW CALCULATIONS
PRELIMINARY ESTIMATES FOR CONFIRMATION OF CAPACITY STATEMENT

Project: McGibbon Development 71 - 79 Main Street South
Job No.: 1967-5752

Date: 10/20/2020

5. *Duration*

| Required Duration of Fire Flow | |
|--------------------------------|---------------------|
| Flow Required L/min | Duration (hours) |
| 2,000 or less | 1.0 |
| 3,000 | 1.3 |
| 4,000 | 1.5 |
| 5,000 | 1.8 |
| 6,000 | 2.0 |
| 8,000 | 2.0 |
| 10,000 | 2.0 |
| 12,000 | 2.5 |
| 14,000 | 3.0 |
| 16,000 | 3.5 |
| 18,000 | 4.0 |
| 20,000 | 4.5 |
| 22,000 | 5.0 |
| 24,000 | 5.5 |
| 26,000 | 6.0 |
| 28,000 | 6.5 |
| 30,000 | 7.0 |
| 32,000 | 7.5 |
| 34,000 | 8.0 |
| 36,000 | 8.5 |
| 38,000 | 9.0 |
| 40,000 and over | 9.5 |

L/s Duration
 221.15 3.0

CF CROZIER & ASSOCIATES

REVISED SANITARY FLOW

Project: McGibbon Development 71 - 79 Main Street South
Job No.: 1967-5752

Revised: 20-Oct-20

A. Proposed Development

| Residential Unit Type | Total Res. Units |
|-----------------------|------------------|
| One Bedroom | 68 |
| Two Bedroom | 94 |
| Three Bedroom | 7 |
| Totals | 169 |

Site area = **0.2773** ha

Population per Hectare = $\frac{1.68 \text{ ppu} * (\# \text{ units})}{\text{area}}$
 Population per Hectare = 1024 p/ha
 Total Population 284 capita

Note 1: Population density per email confirmation from Tim Skrins - Region of Halton, dated September 29, 2015

B. Proposed Flow

| Unit Type | Gross Floor Area (m ²) | Site Area (ha) | Population ² | Average Sanitary Flow | | Harmon Peaking Factor ³ | Peak Flow L/s |
|--------------------------|---------------------------------------|-------------------|-------------------------|-----------------------|-----------------------|------------------------------------|------------------|
| | | | | (L/s) | (m ³ /day) | | |
| Residential | 15,578 | 0.277 | 284 | 0.90 | 78.08 | 4.07 | 3.72 |
| Commercial and Amenities | 369 | | 3 | 0.01 | 0.91 | | |
| Total | | | | | 0.91 | | |

Note 2: Commercial flows designed using 90 person per Hectare. Table 3-2, Halton Water Wastewater Linear Design Manual

Note 3: Peaking Factor = Harmon Formula, Updated per Halton Region Design Guidelines Version 4.0, April 2019

C. Infiltration

| Site Area (ha) | Infiltration Rate ⁴ (L/ha/s) | Total Infiltration (L/s) |
|----------------|--|-----------------------------|
| 0.2773 | 0.286 | 0.08 |

Note 4: Infiltration = 0.286 L/ha/s Section 3.2.4, Halton Water Wastewater Linear Design Manual

D. Total Proposed Site Flow

| | Peak Flow (L/s) |
|---------------|-----------------|
| Proposed Flow | 3.72 |
| Infiltration | 0.08 |
| Total | 3.80 |

Proposed Design Flow

The sewage design flow from the proposed development is: **3.80 L/s**

The Regional Municipality of Halton
1151 Bronte Road
Oakville ON L6M 3L1

Dear Sir/Madam:

**Re: Water Usage and Sanitary Discharge Report for 69-79 Main Street South and 94-98 Mill Street,
Town of Halton Hills, ON**

Background

Amico Affiliates proposes to construct a commercial/residential building with a footprint of 2,452 m² at 69-79 Main Street South and 94-98 Mill Street, Part of Lot 18, Con.9 in the Town of Halton Hills (Georgetown). The site is currently occupied by commercial/residential properties. The site has an area of 0.28 ha and no landscaping is proposed.

The Region of Halton Water and Wastewater Linear Design Manual (April 2019) has been used to calculate the water usage and sanitary discharge for occupant loadings. The proposed development does not require process or cooling water.

Water Usage

Residential/Commercial Building

- ◆ Occupant Load 275 L/cap/d x 284 occupants (Residential)
 =78.1 m³/d
 24, 750 L/ha/day x 0.037 ha (Commercial)
 =0.92 m³/d

Total water usage = 79.02 m³/d (0.91 L/s)

Sanitary Discharge

Residential/Commercial Building

- ◆ Occupant Load 275 L/cap/d x 284 occupants (Residential)
 =78.1 m³/d
 24, 750 L/ha/day x 0.037 ha (Commercial)
 =0.92 m³/d

Total sanitary discharge = 79.02 m³/d (0.91 L/s)

Sincerely,

C.F. CROZIER & ASSOCIATES INC.



Madeline Carter, P. Eng.
Project Engineer